DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 *of* ____
PROPERTY ID #: _____
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: PRIDE HOMES APPLICATION DATE 7/06
ADDRESS: DATE EVALUATED: _____
PROPOSED FACILITY: RES PROPOSED DESIGN FLOW (.1949): RES PROPERTY SIZE: _____
LOCATION OF SITE: NORMAN WOODS LOT 61 PROPERTY RECORDED: Y
WATER SUPPLY: X Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: X Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: X Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
B1	LSS 0-5%	0-26	RC MFSyk	fri SSSP Sesp	N/A	48"	N/A	N/A	PS .3
		26-48	RC MFSyk	fri SSSP Sesp					
B2	LSS 0-5%	0-48	RC MFSyk	fri SSSP Sesp	N/A	48"	N/A	N/A	PS .3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	900 ft²	N/A
System Type(s)	PPBPS	N/A
Site LTAR	.3	N/A

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: ROLLANS SOIL & ENVIRONMENTAL
OTHER(S) PRESENT: _____

COMMENTS: