IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135989 PIN# 4636 62 8276 DATE 6/21/06

OWNER OR APPLICANT Pride Homes Inc. PHONE: Business 704-664 Home

ADDRESS 578 Normandy Rd. Mooresville, NC. 28117

LOCATION 1100 TL Stutts Rd TL Woodstream, Property on (R) near end of current road

SUBDIVISION Normans Woods BLOCK / SECTION LOT 44 LOT AREA .47ac SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 1013 Date 8/23/06

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 960 Linear Feet 320

No Lines 8 (4+4) Trench Width 2' Max Trench Bottom Depth 3'

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Flow Divider 2513 PPBPS

Repair System Description: L 83 RECORDING

Maintenance Agreement Required: ☐ Yes ☒ No

☐ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth No ☐ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: See Site Plan by Rollins Soil + Environmental. Discussed using Pressure Distribution and only 4 lines - Pride declined pressure system.

Comments:/Conditions:

INITIAL SITE SKETCH

(1) Flow Divider

(2) Two Distribution Boxes are Required on this system.

Lee Rollins

Soil + Environmental Svcs.

Site Plan.

AS BUILT SKETCH

The proposed / existing Deck (Revised) addition does not appear to impact the existing septic system.

**NOTE: Must keep deck min 25' from well

Maria Dotson R.S.

Date: 8-27-12

ICHD-Environmental Health Division

The proposed / ~~existing~~ Pool & Deck addition does not appear to impact the existing septic system.

**NOTE: Keep deck foundation min. 25' from well

Cindy Melville R.S.

Date: 6-11-12

ICHD-Environmental Health Division

see attached site plan

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X Ronnie Brame date 6/23/06

Improvement Permit by: Wendy Sparks RS. date 6/21/06

Authorization to Construct by: Wendy Sparks RS date 6/21/06

Installed by: C+S

Operation Permit by: Joseph E Allen date 10/11/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK