DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2K26A2
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Steve Taylor OWNER: AGENT: PHONE:
ADDRESS: 3105-B High Glen Dr. Charlotte APPLICATION DATE: DATE EVALUATED: Jan 20, '94
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: 105' x 217'
LOCATION OF SITE: Bridal Path Pt. ; lot 2
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-10"	gr - scl	1:1/ vfr			PS	—	.6
		10-32	SAB - sic	1:1/ Sticky Sft			PS	—	.3
		32-48	wk SAB - sicl	1:1/ fr			PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DL Hamm, RS OTHER(S) PRESENT: Steve Taylor
COMMENTS: Site can be reclassified PS per rule .1956 modified systems PTBPS