4636638097

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R. A. Klemm DATE 7-14-76 PERMIT NO. 1816

PHONE Business _____ Home _____

LOCATION 1100 TL on 1112 1st Rt TL on corner

S. R. No. _____

SUBDIVISION NAME Norman Woods LOT NO. 23 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3 Character & Porosity of Soil Sandy clay loam (Porosity good)


Garbage Disposal Unit Yes (✓) No ( ) Percolation Rate Soil borings

Auto. Dishwasher Yes (✓) No ( ) Topography > 5-20 + slope

Auto. Wash Machine Yes (✓) No ( ) Depth to Water Table 10'+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations none

Lot Area Ample



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Grade lot to keep water off Septic Tank System.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-14-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold