4636638669

IREDELL COUNTY HEALTH DEPARTMENT

163 Wood Stream Cir.

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert B. McClure DATE 12-17-95 PERMIT NO. 281

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1112 1st Rt To left in Norman Woods S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 2 3/4 acres

Character & Porosity of Soil Clay loam (Porosity Fair)
Percolation Rate 40 to 60 min
Topography Level to 20% Slopes
Depth to Water Table 8' to Lake level
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
3 x 50 = 150'
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )
Ditch 7½' x 100'
3/11/96
Installed by J. R. Boulles

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Attach Drain for washing machine Waste water 5' x 50' 2 lines. Do not connect any sinks to this drain.

CERTIFICATE OF COMPLETION BY L. C. Mozell DATE 12-19-95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold