IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry Fulp DATE 6-19-74 PERMIT NO. 164

PHONE: Business 722-0376 Home 769-2681

LOCATION 150 west TL on 1109 Then TRon 1100 2mi TL on dirt st. a tend on right S. R. No. 1100

SUBDIVISION NAME Neel Acres LOT NO. 9 SECTION OR BLOCK NO. ____


House (✓) Mobile Home ( ) Business ( ) Other ____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 acre

Character & Porosity of Soil Sandy clay loam (Porosity good)
Percolation Rate Not taken
Topography 3 to 12% Slopes
Depth to Water Table 8 to 10' above Lake Level
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 600 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Ditch is close to Lake at corner. However bottom is 8' above Lake Level. This was a difficult lay-out where cabin and well was located.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 6-19-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold