8451

IREDELL COUNTY HEALTH DEPARTMENT

4636 648618

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jeff Shoe DATE 2/15/88 ~~PERMIT~~ NO. 21 A

PHONE: Business _____ Home _____

LOCATION 1100 TL Canvasback TR Old Squaw TL Billy Joels Blind TR Pintail On R. nearend S. R. No. _____

SUBDIVISION NAME Mallard Way Mallard Head LOT NO. 197 SECTION OR BLOCK NO. _____

Tax #: 2K-12-A197

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clayey
Percolation Rate .35 gpd/ft²
Topography 2%
Depth to Water Table 41+
Rock or other impervious formations none

Lot Area 20000

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System N.T.S.

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 2/15/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

GONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold