IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dean Honeycutt DATE 4-10-87 PERMIT NO.

PHONE: Business Home

LOCATION 100 TL Mallard Way (main entrance) on left at corner with Drake Drive S. R. No.

SUBDIVISION NAME Mallard Head LOT NO. 8 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Easement Yes (✓) No ( )
Lot Area .57Ac. (40'x70' easement area in fairway)

Character & Porosity of Soil clay
Percolation Rate 2.4
Topography 8-10%
Depth to Water Table 4'
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1000 gal pump tank



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3 rows 16' TJ
Sq. Ft. Linear Ft. panels
Depth of Stone in Lines
Water Supply: Individual ( ) 200' TOTAL
Public (✓)
Community well

Installed by B J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Alarm not mounted yet.

CERTIFICATE OF COMPLETION BY DR Hinson HD. DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold