4636700291

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C. W. Brewer, Jr. DATE 6/13/89 PERMIT NO. 21C

PHONE: Business _____ Home 663-9669

LOCATION 1100 TL 1112 TL Commodore TR Osprey On R. 2nd lot. S. R. No. _____

SUBDIVISION NAME Commodore Pen I LOT NO. 222 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20000ft²

Character & Porosity of Soil Clay
Percolation Rate 35gpd/ft²
Topography Lvl
Depth to Water Table 4'+
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines ~3
Sq. Ft. _____ Linear Ft. 175' of
Depth of Stone in Lines 16" Trand
Water Supply: Individual ( ) J panels
Public (✓)

Installed by Wayne Arbison

I understand and agree to install septic tank system as specified on this Improvements Permit

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Ran into buried trash/vegetation - Shortened last ditch into 2 short ditches with a flow divider. - ACP.

CERTIFICATE OF COMPLETION BY Andre C. Pierce, RS. DATE 6/13/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold