IREDELL COUNTY HEALTH DEPARTMENT

15437

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Spear Construction DATE Jan. 27, '93 PERMIT NO. 26-6A-231

PHONE: Business _____ Home _____

LOCATION 1100 TL 1112 TL 1st 1212 (Commodore Loop) on right past Osprey Lane S.R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 231 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~15,000 ft²

Soil Characteristics PS clay


Application Rate .3

Topography ~4%

Depth to Water Table 24'

Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. _____ Linear Ft. 200 of

Depth of Stone in Lines 16" PPBS

Water Supply: Individual ☐

Public ☑ CW

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY David R. Henson, RS.

COMMENTS _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold