12032

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Michael Dellinger DATE 10/1/90 PERMIT NO. 26-6-A-233

PHONE: Business _____ Home _____

LOCATION 1100 TL Stutts TL 1st Commodore On right Rt 9 Box 887 Mailbox with cardinal S. R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 233 +232 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		As clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		no 3
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		1-5%
Site Suitable	Yes ( )	No ( )	Depth to Water Table		+3'
			Rock or other impervious formations		none obs.

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System Commodore

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 6
Sq. Ft. — Linear Ft. 240'
Depth of Stone in Lines T+J

Water Supply: Individual ( ) Public (✓) C.W. 16" Panel

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Michael D Dellinger

IMPROVEMENTS PERMIT BY Sam Ingram EHS

COMMENTS: Flow divider 2 Distribution Boxes 3 lines each 4:2 reducers with speed levelers Existing tank must be pumped and filled in with soil. Existing drainfield should be excavated enough to maintain 5' separation from new foundation.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

12-7-90 TANK to be moved to 5' off lower corner - 10' from house line and 3 - 80' rows of panels installed - lowest bottom 5' off

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold