4636711715

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David J. Taylor DATE Sept 7 '78 PERMIT NO. 213

PHONE: Business 523-1234 Home

LOCATION 1100 T.L. on 1112


S. R. No.

SUBDIVISION NAME Norman Shores LOT NO. 25 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ½ Ac.

Character & Porosity of Soil clay loam
Percolation Rate —
Topography 2%
Depth to Water Table 6'-8'
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"+
Water Supply: Individual (✓)
Public ( )

Installed by Jack Stuart
Mack. Co.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY David R. Henson DATE Sept. 7, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold