10578

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mady Construction DATE Oct. 13, '89 PERMIT NO. 2G-17-A-37

PHONE: Business _____ Home _____

LOCATION 1100 TL 1112 (Stutts Rd.) TL 1282 (Woodstream Dr.) near end on left S. R. No. _____

SUBDIVISION NAME Norman Woods LOT NO. 37 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	no 35 - fe 4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2%
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	4+
			Rock or other impervious formations	none obs.

Lot Area 20000 ft²+


_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1000 p.t.

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 180'
Depth of Stone in Lines 16" + 2"

Water Supply: Individual (✓) 4 panels
Public ( ) pressure dosed



Plot of System

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ~~X~~ Paul Phillips

Pump specs: 18 gal/min at approx 14' TDH
Dose approx 120 gal per 6 to 8 min cycle

IMPROVEMENTS PERMIT BY David R. Hinson, RS.

COMMENTS: No trenches deeper in any spot than 36" to trench bottom. Use 1¼" Sch 40 thru panels with ONE 5/32" hole per panel. Two foot pressure head per ditch. Driveway must go next to lot line as shown.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

6-29-90