4630712340

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Meredith DATE 8-2-99 PERMIT NO. _____

PHONE: Business 876-5561 Home 536-3323

LOCATION Plat TL on NC 2nd Paved Rt TL at end 163 Peninsula Drive - Mrsvl. S. R. No. _____


SUBDIVISION NAME Norman Shore LOT NO. 13 SECTION OR BLOCK NO. -

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area _____

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate 2+ rate 100 min/inch
Topography 2 to 4% Slope
Depth to Water Table 10'
Rock or other impervious formations none

Lake



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 700
Depth of Stone in Lines 10
Water Supply: Individual (✓)
Public ( )

Installed by Plato Duckworth

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-2-99

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

145

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Meredith DATE 5-10-99 PERMIT NO. _____

PHONE: Business 396-5561 Home 536-2323

LOCATION 1105 TL on 1117 2nd Paved Rd TL at end

S. R. No. _____

SUBDIVISION NAME Norman Shores LOT NO. 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area .5 acre


Character & Porosity of Soil clay loam Porosity slow

Percolation Rate Soil boring 5

Topography 2% slope

Depth to Water Table 10'+

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field: 5

No. of Lines 2 in each

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by _____

Ditch 5'x95' 2 lines

Tank

Distribution Box

Ditch 5'x75' 2 lines

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Set pipe box so that each ditch receives equal flow

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold