IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Norman Baker DATE 3-2-76 PERMIT NO. 42

PHONE: Business _____ Home _____

LOCATION 1100 Tkoy 112

SUBDIVISION NAME Norman Woods S. R. No. _____

LOT NO. 25 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 1 Acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Not Taken
Topography Slope
Depth to Water Table 8' to 10'
Rock or other impervious formations None



Plot of System

Size of Tank 750 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 330 Linear Ft. 220
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
Washing Machine
800 gal Tank 100 ft Lines
Installed by Pellinger Septic Tanks

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 3-2-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold