IREDELL COUNTY HEALTH DEPARTMENT 4636-74-7814

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Charles Gilley / Burton Dunlap DATE March 12, '93 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION House at 26 Spring Run Drive
Sewer easement behind lot 97 off Canvasback S.R. No. _____

SUBDIVISION NAME ~~Pintail Point~~ Spring Run LOT NO. 21 SECTION OR BLOCK NO. _____
SPRING RUN

House ☑ Mobile Home ☐ Business ☐ Other Type 3 repair

No. Bedrooms 3 No. Bathrooms 2 Soil Characteristics Coastal marsh clay


Garbage Disposal Unit Yes ☐ No ☑ Application Rate ~.3

Auto. Dishwasher Yes ☑ No ☐ Topography ~4%

Auto. Wash. Machine Yes ☑ No ☐ Depth to Water Table > 4'

Lot Area 50'X150' Easement for Septic Rock or other impervious formations None Felt

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tanks Existing Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 24"

Water Supply: Individual ☐
Public ☑ CW

Installed by Bobby Mayhew

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY DRH

COMMENTS New Owner should perform visual inspection of nitrification field at least once every 6 months minimum. Pressure head on existing lines readjusted as of this date. Valves switched so flow goes to new lines.
Operation Permit

CERTIFICATE OF COMPLETION BY DR Hinson, RS. DATE 3/12/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold