Dead lines OK

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Knox, Black, & Briggs, Inc. DATE 6-10-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Building site on Spring Run Drive
Sewer EASEMENT at end of Billy Joe's Blind on Rt. S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 132 SECTION OR BLOCK NO. _____
See Attached Easement

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2-3
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Easement Area Yes (✓) No ( )
Easement Area ~37'X 100'

Easement Area
Character & Porosity of Soil clay
Percolation Rate 2 to 3
Topography 2 to 4+
Depth to Water Table _____
Rock or other impervious formations none obs.

Spring Run DRIVE

1250 gal pump tank

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. 200'±
Depth of Stone in Lines 16" T&J panels
Water Supply: Individual ( )
Public (✓)
pressure-dosed

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

(✓) Signed: _____

IMPROVEMENTS PERMIT BY D R Hinson, R.S.

COMMENTS: TANK positions may be adjusted as needed on building lot as long as it meets minimum setbacks required. Pressure dosed 200'± 16" T&J panels in lot 132 EASEMENT. Will need house whatever size pump necessary to get 2' of pressure head on panels. Pump line to be color coded if in same ditch as line to lot 133 EASEMENT.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold