4636 76 8245

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Knox, Black & Briggs, Jr. DATE 5/15/89 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Building site on Spring Run Drive. Drainfield easement at end of Billy Joes Blind on Rght. S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 133 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms ~3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	sandy clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	3
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	22%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	1'+
easement Area 37'x105'			Rock or other impervious formations	none observed

_____ Basement with Plumbing _____ Basement without Plumbing No Basement

P.T. 1500 gals.



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. _____ Linear Ft. 200' of
Depth of Stone in Lines 16" T & J Panel

Water Supply: Individual ( ) pressure dosed
Public (✓)

Installed by Bobby Mayhew

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH, R.S.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andre C. Pierce, R.S. DATE 5/15/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold