Rec'd 2 lines OK

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Knox, Black, & Briggs Inc. DATE 6-10-87 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Building site on Spring Run Drive Sewer Easement at end of Billy Joe's Blvd on Rt. _____ S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 133 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2-3

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Easement Area

Lot Area ~37'X105'

Character & Porosity of Soil clay

Percolation Rate ~3

Topography 2%

Depth to Water Table 41+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

1250 gal pump tank

ST Size of Tank 1250 Gals.

PT Nitrification Field:


No. of Lines 2

Sq. Ft. _____ Linear Ft. 200' @ 16"

Depth of Stone in Lines T&J panels

Water Supply: Individual ( )

Public (✓) pressure dosed



Plot of System

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed _____

IMPROVEMENTS PERMIT BY O. R. Hunsucker, R.S.

COMMENTS: Tank positions may be adjusted as needed on building lot as long as it meets minimum setbacks required. Pressure dose 200' @ 16" T&J panels in Easement Area specified. Will need to use whatever size pump necessary to get 2' of pressure head on panels. Pump line to be color coded if used in same ditch as 132.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold