4636771542

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Thompson Building DATE 6-21-79 PERMIT NO. 214

PHONE: Business _____ Home _____


LOCATION 1100 TL on 1179 TL on 1st St. TL on 1st paved St at end on left S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 21 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4 ft.
Lot Area ½ AC			Rock or other impervious formations	none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)
Community Well
Installed by Jon Thompson

IMPROVEMENTS PERMIT BY Mark R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Mark R. Hinson DATE 6-21-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold