4636771810

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Thomasson Builders DATE 10/29/79 PERMIT NO. 376

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1179 TR on 1st paved St. TL on 1st paved St. near end on Rt. Bufflehead Dr. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 16 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area ½ AC +

Character & Porosity of Soil clay loam
Percolation Rate 80 mpi
Topography 6%
Depth to Water Table mark. more otr.
Rock or other impervious formations

Size of Tank 1500 Gals.
Nitrification Field: /
No. of Lines _____
Sq. Ft. _____ Linear Ft. 150' of panels
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )



Plot of System

Installed by Richard Abernathy

IMPROVEMENTS PERMIT BY D. R. Johnson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Johnson DATE 10/29/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold