4636772809

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Thomasson Builders DATE 8-29-79 PERMIT NO. 393

PHONE: Business _____ Home _____

LOCATION 1100 ft into Mallard Head Buffalohead Drive

SUBDIVISION NAME Mallard Head LOT NO. 15 SECTION OR BLOCK NO. 1 S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ~½ AC.

Character & Porosity of Soil clay loam
Percolation Rate 60-80 mpi
Topography 4-6%
Depth to Water Table unk.
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 1 row panels
Sq. Ft. _____ Linear Ft. 135'
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)
Community Well
Installed by Leon Thompson

IMPROVEMENTS PERMIT BY D. R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 8-29-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold