4636773906

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Thomasson Builders DATE June 8, 1979 PERMIT NO. 198

PHONE: Business _____ Home _____


LOCATION 1100 TL on 1179 TR on 1st paved rd. T.L on 1st paved rd ¼ mi. on Rt. S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 14 SECTION OR BLOCK NO. 2

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 mpi +
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4 ft.
Lot Area ½ AC. +			Rock or other impervious formations	none obs.



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 16"+

Water Supply: Individual ( )
Public (✓)

Installed by Leon Thompson

IMPROVEMENTS PERMIT BY D R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 6-8-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold