IREDELL COUNTY HEALTH DEPARTMENT 4636 829447

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Crest Builders DATE 4/10/89 PERMIT NO. 21A

PHONE: Business _____ Home 843-4764

LOCATION 1100 T.L. Canvasback TL Highland TR Highland Place S. R. No. _____

SUBDIVISION NAME Woodland Hills LOT NO. 22 SECTION OR BLOCK NO. 3


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.4 gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Good
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observed

Lot Area 20000 ft²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System N.T.S.

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)
C. Well

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP

COMMENTS: Mr. Swancerek changed plans to a 3BR house 3/31/89. -ACP. → Michael P. Leazar called.

CERTIFICATE OF COMPLETION BY Andrew C. Pierce DATE 4/10/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold