IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 172807 PIN # 4636 83 1357 DATE June 7, 2012

OWNER Wesley Dumitru Zdrentan APPLICANT: Same PHONE: Home/Cell # 704-658-5106 Business #

SITE ADDRESS 253 Spring Run Dr. Mooresville OWNER / APPLICANT ADDRESS 406 Canvasback Rd Mooresville 28117

SITE DIRECTIONS Brawley School Rd TL Canvasback TR Spring Run 3rd on right

SUBDIVISION Mallard Head BLOCK / SECTION 1 LOT # 110 LOT AREA .49 Ac DESIGN FLOW 480 gpd L.T.A.R. .275 gpd/ft²

Septic Tank 1000 Gallons: STB 875 Date 4-10-12

Pump Tank ____ Gallons: P T ____ Date ____

Pump Make ____ Model ____ Serial # ____

No. Nitrification Fields: 1 No. Lines 8 Linear Feet 296

Trench Width 24" Max. Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: PPBPS Gravity

Repair System Description: LP PPBPS max. feasible Rule .1945

Maintenance Agreement Required ☐ YES ☒ NO

Gravel Depth NA ☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons ____

☐ Other No. Employees ____

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

Flow splitters and divided T must be bedded on level concrete pads

Suggest pavers instead of concrete if place walkway in front of house near repair

INITIAL SITE SKETCH

See Plan From Rollans Soil & Environmental Services

Approved by ICHD

AS BUILT SKETCH

INSTALLED AS SHOWN ON PLAN

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☒ ***IMPROVEMENT PERMIT*** *with plat valid without expiration. site plan valid 60 mo.* ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: [signature] Date 6-11-12 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: [signature] REHS Date 6-7-12 OPERATION PERMIT by: [signature] REHS Date 9-7-12

AUTHORIZATION TO CONSTRUCT by: [signature] REHS Date 6-11-12 Existing System Inspected by: ____ REHS Date ____

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant