P. O. BOX 33189

DUKE POWER COMPANY
GENERAL OFFICES
422 SOUTH CHURCH STREET
CHARLOTTE, N. C. 28242

TELEPHONE: AREA 704
~~373-4011~~
373-6456

August 29, 1983

Mr. Mike Trent
Leak Trent, Inc.
1410 Brevard Court
Charlotte, NC 28206

Dear Mr. Trent:

Duke Power Company will not object to your proposal dated July 28, 1983, which will involve our Lake Norman Loop (East) Transmission Line right-of-way.

Your proposal is for a single excavation not to exceed 24 inches in width for each property. Duke Power will not object provided the construction is according to our restrictions listed below.

1. No sewer line shall parallel on the right-of-way.

2. Sewer line may cross at an angle no less than 30 degrees with the center line.

3. No septic tanks shall be installed on the right-of-way.

If towers or poles are involved:

4. Sewer lines shall be 20 feet from a tower or pole.

5. Grading shall be 20 feet from a structure or attachment at ground line and slope shall not exceed 3:1.

6. Grading or fills shall not lower the clearance of conductor to ground below 25 feet under 44 kV, 27½ feet under 100 kV, 35 feet under 230 kV, or 45 feet under 525 kV.

If your proposal changes during construction, you will be expected to contact this office at telephone number 331-4166.

If we can be of further service, please call.

Sincerely,

Billy R. Yandle

Billy R. Yandle
Field Representative

jla

xc: Mr. C. H. Hendrix