4636835914

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Martin DATE 9/10/87 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TL 1179 (Canvasback) on R. ~1/8 mi. b/f. jct w/ Spring Run Drive S. R. No.

SUBDIVISION NAME Mallard Head LOT NO. 102 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	Character & Porosity of Soil Clayey
Auto. Dishwasher	Yes	(✓)	No	( )	Percolation Rate ~3 gpd/ft²
Auto. Wash. Machine	Yes	(✓)	No	( )	Topography 2-4% depressional
Site Suitable	Yes	(✓)	No	( )	Depth to Water Table 41+
					Rock or other impervious formations none observed

Lot Area 20000ft²+

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. Linear Ft. 200' 16"
Depth of Stone in Lines T&J Panel

Water Supply: Individual ( )
Public (✓)

Installed by Yountz

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY DRH.

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 9/10/87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold