4636-84-5005

10560

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Rambo DATE Feb. 20, 1990 PERMIT NO. 2K-9-A-101

PHONE: Business _____ Home _____

LOCATION 1100 TL 1179 (Canvasback) on right just before Spring Run Drive S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 101 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site ~~Suitable~~ PS	Yes	( )	No	( )

Character & Porosity of Soil clay
Percolation Rate .3-.4
Topography 2-4%
Depth to Water Table 4' +
Rock or other impervious formations none obs.

Lot Area 125' x 160'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 6
Sq. Ft. _____ Linear Ft. 196'
Depth of Stone in Lines 16" T+I

Water Supply: Individual ( ) Panel
Public (✓)

Installed by F J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: 4:2 reducers used Flow dividers used

CERTIFICATE OF COMPLETION BY Sam Ingram EHS DATE Feb. 20, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold