4636-85-4651

IREDELL COUNTY HEALTH DEPARTMENT

11405

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dennis Little DATE 3/6/91 PERMIT NO. 2K-9-A-62

PHONE: Business _____ Home _____

LOCATION 1100 (Brawley School) TL on 1179 (Conover Back) TR on Old Squaw, TL onto Billy Joes Blind, next to last house on (L) before road ends S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 62 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2


Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 125' X 160'

Character & Porosity of Soil AS / clay
Percolation Rate 3
Topography 2-4%
Depth to Water Table 40"
Rock or other impervious formations None observed

12'X16' SHED

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4 @ 100'
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by F T Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

The proposed / existing SHED addition does not appear to impact the existing septic system.
**NOTE: 12X16' SHED

R.S.
Date: 2-27-91
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trenches shallow no deeper than 30" to trench bottom. Water line cannot be routed across drainfield.

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 3/6/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold