4636856128

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Spear Construction DATE 5/4/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 (Brawley School Rd.) T.L. Canvasback .8 mi on R. (BRICK HOUSE)

SUBDIVISION NAME Mallard Head LOT NO. 92 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20000 ft² +

Character & Porosity of Soil Clayey
Percolation Rate ~.35 gpd / ft²
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System NOT TO SCALE

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1029 Linear Ft. 343
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (X)
COMMUNITY
Rowan Septic Tank
Installed by George Kirkpatrick

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: House plan was completely reversed. OK to do so.

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 5/4/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold