DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET: 1 OF 1
PROPERTY I.D.#: 2K9R80
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jeff Pelebet for Jack Raney OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 12/20/93
PROPOSED FACILITY: 3 Bedroom SF Dwelling
PROPERTY SIZE: 125' x 160'

LOCATION OF SITE: Lot 89 Mallard Head
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-8"	SAB/CL	1:1/fr	—	—	PS	—	.05
		8-40+	SAB/C	1:1/fi st. Stratified	—	—	PS	—	.04
2									
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .04
EVALUATED BY: DH Hanson OTHER(S) PRESENT: Jeff Pelebet
COMMENTS: