09679

4636-87-3279

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Concordia Construction DATE Aug 30, '89 PERMIT NO. 2K-9-A-40

PHONE: Business 633-0394 Home

LOCATION 1100 TL 1179 (Canvasback) TR Old Squaw Trail ~ 400' on Right

S. R. No.

SUBDIVISION NAME Mallard Head LOT NO. 40 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site ~~Suitable~~ PS	Yes (✓)	No ( )

Lot Area 120'X 167'

Character & Porosity of Soil Clay
Percolation Rate ~.25
Topography 2%
Depth to Water Table 4'7
Rock or other impervious formations none obs.

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. Linear Ft. 240'
Depth of Stone in Lines 16" T&J
Water Supply: Individual ( ) panels
CW Public (✓) G.F.

Installed by Rowan Septic TK.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY

COMMENTS: Beginning of drainfield slightly deeper than preferred due to shaping of the lot to provide drainage (surface) away from the house.

CERTIFICATE OF COMPLETION BY Jack K. Henson, RS DATE Aug 30, '89

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold