DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Doris Steer OWNER: ✓ AGENT:__ PHONE:_____
ADDRESS: Rt 4 #34 Mocksville APPLICATION DATE:_____ DATE EVALUATED: 9/27/93
PROPOSED FACILITY: 3 bedroom SF dwelling
PROPERTY SIZE: 1.20 ± /671
LOCATION OF SITE: Lot 38, Mallard Head on Old Sowden
WATER SUPPLY: On-Site Well____ Comm. Well____ Public____ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
middle rear 1/3 of lot	55	0-17"	gr SaL / ~~SaCL~~	1B1 / fr	—	—	PS	—	.05
		17-24"	gr / cl	1B1 / efi	—	—	PS	—	.03
		24-48	SaL / c	1B1 / vfi	—	—	PS	—	.03
2									
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .03
EVALUATED BY: [signature] PS OTHER(S) PRESENT: Doris Steer
COMMENTS:_____