DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Howard Neal
APPLICANT: ___
ADDRESS: 336 Woodland Rd.
APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: .68
LOCATION OF SITE: Lot 34 Lakeside Farm PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☒ Other Community System
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Foot 6-8% unfam T	0-7	Fr sdk / cl	Fr ss - sp	P - B	PS			.3
		8-34	mw cl mic	Fr ss - sp	P - R				
		35-48	fi sl	Fr ss - sp	P - B-R				
2	Rear L 4-5%	0-6	sdk - l	Fr ss - sp	- B	PS			.3
		7-26	mwk - hcl	Fi ss - sp	- R				
		27-48	mfi - sdk mic	Fr ss - sp	P - R-B				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	P	P
System Type(s)	T+3	16" PPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): odd situation for house
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Sparks
OTHER(S) PRESENT: B Linn Lanyon