9376

4636-88-2077

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harry Stegall DATE 5/30/89 PERMIT NO. 21A

PHONE: Business _____ Home 872-2593

LOCATION 1100 TL Canvasback TR Drake ~ ¼ mi. on R. (4th lot on R.) S. R. No. _____

SUBDIVISION NAME Mallard Head LOT NO. 1B-8 SECTION OR BLOCK NO. _____

Tax No. 2K-10-A-1B

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable P.S.	Yes (✓)	No ( )	

Character & Porosity of Soil Clay
Percolation Rate 4
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement Crawl space



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)
Community H2O

Installed by Ballard Grading

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andre C. Pierce

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andre C. Pierce DATE 5/30/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold