ON-SITE WASTEWATER SECTION

COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dean Davis APPLICATION DATE

ADDRESS:

PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): DATE EVALUATED: 11-1-2000

LOCATION OF SITE: Josh Acres Sale PROPERTY SIZE:

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other PROPERTY RECORDED:

EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Ridge	0-14	Brw SCL	GR FR					
		14-48	Rd/Brw C/CL	m-WSBK SS,SP,SE, F-FR					.25
			w/ Few Yellow/Brw mottles						
			Note: Some wetness in hole						
2	Ridge Shoulder	0-15"	Brw SCL	GR FR					
		15-48"	Rd/Brw C/CL	m-WSBK SS,SP,SE					PS
			F-FR w/Very Few Yel/Brw mottles						.3
			& Common Mica Flakes						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):

SITE CLASSIFICATION (.1948):

EVALUATED BY:

OTHER(S) PRESENT:

COMMENTS: