DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Newman McDade OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 7/6/94
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE:
LOCATION OF SITE: Lot 1, Regency Lake
WATER SUPPLY: On-Site Well ___ Comm/Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-8"	SAB/scl	1:1/fr-vfr			PS		.6
		8-27	SAB/c	1:1/fi-vfi					.4
		27-48	WKSAB/sicl(B-C)	1:1/fi-vfi					.3
2	LS	0-7"	SAB/cl	1:1/fi-vfi			PS		.5
		7-28	SAB/c	1:1/fi					.4
		28-48	WKSAB/sicl	1:1/fi-vfi					.3
3									
4									
5									

AVAILABLE SPACE (.1940): U SITE CLASSIFICATION (.1948): U-X SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DHinson, IRS OTHER(S) PRESENT: Richard Abernathy, Newman McDade
COMMENTS: Site can be reclassified PS per rule .1956 modified systems PBPS
Limited system to be conventional w/ PBPS repair.