IREDELL COUNTY HEALTH DEPARTMENT 4636925018

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. O. IN MAN, Builders DATE 5-23-84 PERMIT NO. 154

PHONE: Business _____ Home _____

LOCATION 1108 TO 1179 go to end bear left 6th on R


SUBDIVISION NAME Woodland Hills S. R. No. _____ LOT NO. 6 SECTION OR BLOCK NO. 1

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
~~Auto. Wash. Machine~~ Yes (X) No ( )
Site Suitable Yes (X) No ( )
Lot Area 20,000 ft²

Character & Porosity of Soil Clay loam
Percolation Rate 0.5 gal/ft²/day
Topography 2 & 4
Depth to Water Table _____
Rock or other impervious formations None obs




Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1440 Linear Ft. 480
Depth of Stone in Lines 12"
Water Supply: Individual
Public Community H2O
Installed by J. R. Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-23-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold