4636925148

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charlie Weatherman DATE 5-21-85 PERMIT NO. 222

PHONE: Business _____ Home _____

LOCATION 1100 R 1179 go to end bear left Lot on R before Woods

S. R. No. _____

SUBDIVISION NAME Woodland Hills LOT NO. 7 SECTION OR BLOCK NO. 1

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area 20,000 ± SF

Character & Porosity of Soil Clay loam
Percolation Rate 0.5 gal/ft²/day 2-10 Min/in
Topography Gently
Depth to Water Table 4'+
Rock or other impervious formations NONE obs.

_____ Basement with Plumbing X Basement without Plumbing _____ No Basement



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual X
Public X
Ind. Well for Heating

Installed by F. J. Erwin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Lot line
Relayout to single trenches

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-21-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold