IREDELL COUNTY HEALTH DEPARTMENT

12872 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Cecil Hood DATE 6/13/91 PERMIT NO. 26-19-A-100

PHONE: Business _____ Home 473-2437

LOCATION Ring Neck Trail, Brawley TL on Conesbrak, TL into Woodland Hills TR first Rt into Ring Neck Trail on Rt ~ 1/4 mile S. R. No. _____


SUBDIVISION NAME Woodland Hill LOT NO. 100 & 100A SECTION OR BLOCK NO. Sec 2

House (✓) Mobile Home ( ) Business ( ) Other Pressure dosed T+T Panel

No. Bedrooms 4 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000 FT2

Character & Porosity of Soil clay - clay loams.
Percolation Rate .4
Topography 2-10%
Depth to Water Table >48"
Rock or other impervious formations NONE FOUND

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

1000 - SEPTIC TANK
Size of Tank 1000 - PUMP TANK Gals.
Nitrification Field:
No. of Lines 3 @ 70'
Sq. Ft. _____ Linear Ft. 210
Depth of Stone in Lines PER MANUFACTURER
Water Supply: Individual ( )
Public (✓)

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Warren K. Caldwell

10/30/91 – Drainfield completed – AWS

IMPROVEMENTS PERMIT BY Wesley Sparks R.S.

COMMENTS: One 3/16" hole drilled per panel - 2 feet of pressure head per lateral, 24" stand pipes at end of each drain line, approximately 175 gallons per dose. Copy of recorded easement must be supplied before system may be completed. Trenches no deeper than 36" to trench bottom. Drainlines 10' inside prop/lines.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold