4636932410

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Helms DATE 4-23-86 PERMIT NO. 206

PHONE: Business _____ Home _____

LOCATION 1100 TL 1179 TL Ringneck trail (NOW Broadbill) BR of both fork lot on R

SUBDIVISION NAME Woodland Hills LOT NO. 96 SECTION OR BLOCK NO. 4 S. R. No. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000

Character & Porosity of Soil clay
Percolation Rate 0.5 gal/ft²/day
Topography 2-5%
Depth to Water Table 4'
Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1050 Linear Ft. ~~300~~ 360
Depth of Stone in Lines 12"
Water Supply: Individual (✓) Public ( )

Installed by Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY FAC & J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Bennett DATE 4-25-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold