IREDELL COUNTY HEALTH DEPARTMENT 4636937677

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Anne Sherrill DATE 10-15-82 PERMIT NO. 328

PHONE: Business _____ Home _____

LOCATION 1100 TL 1179 Pass Reynolds Real Estate TL Ring Neck Trail on left on lake S. R. No. _____

SUBDIVISION NAME Woodland Hills LOT NO. 90 SECTION OR BLOCK NO. 4

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Clay loam
Percolation Rate 16 sal/sq'/day
Topography 5 to 8%
Depth to Water Table bottom of lower ditch 5.5' above lake (High water mark)
Rock or other impervious formations none

Lot Area 20,000 sq'

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

1000 upper ✓
Size of Tank 1000 lower Gals.
Nitrification Field:
No. of Lines 3 upper 3 lower
Total Sq. Ft. 1050 Linear Ft. 350
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Richard Abernathy ✓

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer ✓

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 10-15-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold