07783

after 2:00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gayle B. Peters DATE 2/1/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TL 1179 TL PINTAIL RUN TR RING NECK TRAIL BEAR LEFT ~ 500' on Left. S. R. No. _____

SUBDIVISION NAME Woodland Hill LOT NO. 88 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3 ACP

Garbage Disposal Unit	Yes (✓)	No (✓)	Character & Porosity of Soil	Clayey	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	~.4 gpd 1/ft²	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4 → 10%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
			Rock or other impervious formations	none observed	

Lot Area 20000ft²

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System N.T.S.

Pumptank 1250 gals.

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)
Community system

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X _____

IMPROVEMENTS PERMIT BY André C. Prince

COMMENTS: SET TANKS NEAR HOUSE (5' off basement if at lower level) RUN 2" sch 40 PVC from Pump Tank to series of ditches head with 2" ball valves. Nitrification lines of 1½" w/ 5/32" hole every 5'. 2' of pressure head in each ditch. High water alarm & float to be set. Pump should be able to dose 25 gpm w/ 26' TDH.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold