IREDELL COUNTY HEALTH DEPARTMENT 463694448862

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul B. Reynolds DATE 2/9/89 PERMIT NO. 21A

PHONE: Business _____ Home 637-3254

LOCATION 1100 TL 1179 (Canvasback) TL Woodland Hills On left ~ ½ mile

SUBDIVISION NAME Woodland Hills LOT NO. 50 SECTION OR BLOCK NO. 6 S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 20000 ft² +

Character & Porosity of Soil Clay
Percolation Rate .3
Topography 2%
Depth to Water Table 4'+
Rock or other impervious formations none obs

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. _____ Linear Ft. 250' of
Depth of Stone in Lines 16" T and
Water Supply: Individual ( ) J panels
Public ( )

Installed by David Miller
Goldhill - Rowan Co.
I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP

COMMENTS: Ea. line is approx 62 - 63'

CERTIFICATE OF COMPLETION BY Cindy C. Rice DATE 2/9/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold