IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12547

OWNER OR CONTRACTOR New Trend Homes DATE 6/11/91 PERMIT NO. 2K-3-A-56

PHONE: Business _____ Home 366-6078

LOCATION Crystal Cir, Brawley TL on Statts, TL on 2nd Woodduck, TR on Crystal Cir TR on Crystal Cir, on R S. R. No. _____

SUBDIVISION NAME Crystal Bay LOT NO. 56 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	A/clay - sf-
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	35
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-3%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	>48'
			Rock or other impervious formations	No

Lot Area 20,000 FT 2

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 5 @ 75' x 3'
Sq. Ft. 1155 Linear Ft. 375
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Laib Septic Svcs.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 6/11/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold