4636971121 II

IREDELL COUNTY HEALTH DEPARTMENT

11403

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Concordia Construction DATE June 13, '90 PERMIT NO. 2K-18-A-32

PHONE: Business _____ Home _____

LOCATION 1100 TL 1179 (Cannadocke) TL Turnberry ~200' on Right

S. R. No. _____

SUBDIVISION NAME St Andrews Village LOT NO. 32 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	~ 4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2B
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none obs.

Lot Area 130' X 175'

_____ Basement with Plumbing _____ Basement without Plumbing ____✓____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓ CW

Installed by Lowes Septic Tank

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hanson, EHS DATE June 13, '90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold