IREDELL COUNTY HEALTH DEPARTMENT 4636974674

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Howard Neel DATE 11-19-80 PERMIT NO. 345

PHONE: Business _____ Home _____

LOCATION 150W TL 1109 TR 1100 TL 1179 TR Woodchuck Road 9th on R

SUBDIVISION NAME Lakeside Farms LOT NO. 26 SECTION OR BLOCK NO. _____ S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (X)	No ( )
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 17,000 ft²

Character & Porosity of Soil Clay loam
Percolation Rate 2-1-30
Topography _____
Depth to Water Table unknown
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (X) Community H2O

Installed by Richard Abernethy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Note: About 3' to top of tank

CERTIFICATE OF COMPLETION BY Fred Clemmer

EXISTING SYSTEM CHECKED BY: _____ DATE 11-19-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold