DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: David Montemuro APPLICATION DATE ___
ADDRESS: 1607 High Ridge Rd. Stanley, NC. 28164 DATE EVALUATED: 9/19/02
PROPOSED FACILITY: 3BR-2BA House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .409
LOCATION OF SITE: 1st Woodlands L.D. - Lot 24 Lakeside Farms PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☒ Other Community
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Flat. T. 2-5%	0-13	sbk cl	FI S SP					.3
		14-36	fr sbk cl	FR SS SP					
		37-48	M.SBK cl	FR SS SP					
2	LS ~5%	0-12	MSBK cl	FR S SP					.3
		13-39	SBK scl	~FI SS SP					
		39-48	WEISBK MGR sl	~FI SS SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	?	
System Type(s)	14" PRPS	Pressure PRPS
Site LTAR	.3	.3

OTHER FACTORS (.1946): Community Water
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: [signature]
OTHER(S) PRESENT: ? No

COMMENTS: ___