IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

4636-97-9791

OWNER OR CONTRACTOR Terry Neal DATE 5/22/89 PERMIT NO.

PHONE: Business Home 892-4966

LOCATION 1100 TL Canvasback TL 1st Wood Duck Lp. ~1/4 mile on L. (lot 12) S. R. No.

SUBDIVISION NAME Lakeside Farm Sec. 1 LOT NO. 12 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay
Percolation Rate ~.35 gpd/ft2
Topography gdp
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area .83A

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

P.T.: 1000 gals

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1020 Linear Ft. 340
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)
Community well

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY A.C.P

COMMENTS: High water alarm cked today - ACP

CERTIFICATE OF COMPLETION BY Andie C. Pierce DATE 5/22/89

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold