VISION O ENVIRONMENTAL HEALTH:
N-SITE W, TEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 13 Regency PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-14	RL SNK	FRI SSSO		INC @ 14"+			PS .35
	14-53	RCL WSNK	FRI SSSP					
	0-5	BSL GR	FRI SSSP		COMMON INCP			PS .4
	5-14	RCL WSNK	FRI SSSP					
	14-57	SL SAPM	FRI NSNP					
	0-25	RBSCL WSNK	FRI SSSP		COMMON SOD			PS .4
	25-60	SL SAP M	FRI NSNP					
	0-30	BSCL/CL WSNK	FRI SSSP		COMMON SOD			PS .35
	30-54	LSAP M	FRI NSNP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
& LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____